


# Sultanate of Oman

Public Authority for Electricity and Water  
General Directorate of Water Operations.



سلطنة عُمان  
الهيئة العامة للكهرباء والمياه  
المديرية العامة للتشغيل

Ref.No SMAC/5-14/2010

Fax: 24562083

Date: 8/1/211

M/s: United Engineering services L.L.C

P.O Box: 2729, Seeb

Postal Code: 111

After Compliments,

**Sub.** DUCTILE IRON FITTINGS Manufactured by KEJRIWAL  
CASTINGS PVT LTD, India

In continuation to your letter seeking approval for the products mentioned in the Subject, we are pleased to inform you that the same are approved to be used in the works pertaining to the Public Authority for Electricity and Water as per the details in the Approval Certificate enclosed herewith.

We appreciate your interest shown and efforts taken to introduce the products to PAEW. Should you stand in need of any further clarification from our side, please do not hesitate to contact the office of the undersigned.


Thanks and Regards

**Eng Zahran bin Salem bin Hamood Al Rashdi**  
**Chairman**  
**Standards and Material Approval Committee**



# Sultanate of Oman

Public Authority for Electricity and Water  
General Directorate of Water Operations.



سلطنة عمان  
الهيئة العامة للكهرباء والمياه  
المديرية العامة للتشغيل

## TO WHOMIT MAY CONCERN PRODUCT APPROVAL- DUCTILE IRON FITTINGS

The Standards and Materials Approval Committee (Water) of the Public Authority of Electricity & Water has examined the following product and all the relevant information submitted about the product and hereby approves its use in PAEW pipeline installation work.

- Name of the Product : DUCTILE IRON FITTINGS up to DN 600 DIA
- Brief Description : Ductile Iron Fittings for conveyance of potable Water. Cement lined, zinc sprayed, bitumen coated socket-spigot or flanged joints with heavy duty polyethylene sleeving.
- Name of the Manufacturer : KEJRIWAL CASTINGS PVT LTD
- Country where manufactured : India
- Local Agent : United Engineering services L.L.C
- Remarks : Pipes & Fittings shall have Pushfit Tyton Joints with rubber rings or flanged joints with full width rubber gaskets. Required quantities of lubricants and 10% extra polyethylene sleeving shall be supplied along with pipe fittings.
- Special Observations : Each consignment shall be accompanied with an Independent inspection/ testing certificate in full compliance with the requirements of MHEW-W02 and ISO 2531 and BS En 545.  
\* Note this approval is granted in consideration of your product meeting with our specifications and we are not bound to purchase the product as its already approved

Date of Approval : 14/12/2010

Date of Expiry : 14/12/2012

Eng Zhran bin Mohammed bin Hamid Al Kindi  
Chairman  
Standards and material Approval Committee